

# Report of Proposals 2014 NEC

27 August 2012

## PV Industry Forum Solar ABCS

John C. Wiles

Southwest Technology Development Institute

New Mexico State University

P.O. Box 30001/MSC 3 SOLAR

Las Cruces, New Mexico 88003

<http://www.nmsu.edu/~tdi> > PV > Codes and Standards

e-mail: [jwiles@nmsu.edu](mailto:jwiles@nmsu.edu)

Phone: (575) 646-6105 Fax: (575) 646-3841



*Southwest Technology  
Development Institute*

# Understanding the Code

## The Code and Electrical Installations Hierarchy:

**Chapters 1-4: General information for all installations**

**Chapters 5-9: Special installations and Equipment**

**Section 110.3(B): Instructions on listed equipment must be followed**

**The AHJ has the final say..... But there is always appeal process**

**UL Standards: Effect the Hardware and the Instructions**



*Southwest Technology  
Development Institute*

# Understanding the Proposals

Know and understand the 2011 NEC

Read the proposals and substantiations and CMP actions in the ROP

Read the comments by CMP members

Note who submitted

Comments may be sent to NFPA or to me for evaluation

See back of NEC for instructions and forms

And here is a brief summary of significant proposals for 690 and 705

**The Draft 2014 NEC has errors and text not approved by the CMP**



*Southwest Technology  
Development Institute*

# Definitions 690.3

**DC Combiner:** One definition for all types of combiners

**Multimode Inverter:** utility interactive plus stand-alone operation

**Photovoltaic System:** Modules to load



*Southwest Technology  
Development Institute*

# 690.4 General Provisions

DC combiners and dc to dc converters must be listed

Conductor installation requirements moved to 690.31

Multiple inverters allowed on a single structure

**Comment: Grouping ?**



*Southwest Technology  
Development Institute*

# 690.5 Ground-Fault Protection

**(A) Ground-Fault Detection and Interruption.** The ground-fault protection device or system shall:  
(1) Determine the pv input circuit has **isolation** prior to export of current,

**Comment: Isolation from What?**



*Southwest Technology  
Development Institute*

# 690.7 Maximum Volatge

(C) One and 2 family dwellings can have **1000** volt systems

**Comment: The CMP did not approve this change**



*Southwest Technology  
Development Institute*

# 690.8 Circuit Sizing and Current

**(5) DC-to-DC Converter Output Current** . The maximum current shall be the dc-to-dc converter continuous output current rating.

**690.8 and 690.9 revised to separate conductor calculations from OCPD requirements**



*Southwest Technology  
Development Institute*

# 690.9 Overcurrent Protection

DC PV circuits require PV Listed Devices

**Comment: Not consistent with 690.17(A)(6) and may not be necessary**

Current limited sources shall be protected at the source of overcurrent

**Comment: Did not make Art 240, but OK here**



*Southwest Technology  
Development Institute*

# 690.11 DC ARC FAULT CIRCUIT PROTECTION

All arcs (series, parallel and ?) must be detected and interrupted

**Comment: Ground fault arcs too?**  
**This may require module level interruption!**  
**Current technical efforts: inverter, combiner, separated detection and interruption**



*Southwest Technology  
Development Institute*

# 690.12 PV Emergency Shutdown

PV systems on the roof of buildings shall:

Ten Seconds after emergency shutdown or when PV power source is opened, PV source circuits shall have no more that 80 volts

**Comment: PV power source? AC or DC disconnect?**

**Emergency Shutdown? What is this?—red button?**



*Southwest Technology  
Development Institute*

# III Disconnecting Means

Sections 690.13, 14, and 15 revised for clarity-14 gone/moved

Only Ungrounded dc conductors require disconnects

PV Systems discos have several requirements specified

**Comment: PV System discos?? AC or DC or both ?**

15(D) DC combiners on roofs must have output circuit load break rated disco inside or within 6 feet



*Southwest Technology  
Development Institute*

## III Disconnecting Means (Continued)

690.17(A): Discos permitted to be power operated but must have manual function during power outages

Listed PV devices allowed including “open” type devices

**Comment: Not consistent with (C): no contact with live parts**



*Southwest Technology  
Development Institute*

# 690.31-Revised

(A): Guarding of conductors over 30V in RAA now allowed

(B): NO DC PV circuits in raceway with inverter ac circuits

**Comment: Misses safety issue and will increase cost**

(D): Multiconductor USE-2 and TC-ER allowed on outputs of inverters where fastened every 6 feet

**Comment: Not clear if MC USE-2 is available or that TC-ER or USE-2 can be unsupported for 6 feet. Across the roof?**

**Comment: Circuit routing (structures) still needed but gone**



*Southwest Technology  
Development Institute*

# 690.35 Ungrounded Arrays

**(C):** (1) Determine the pv input circuit has isolation prior to export of current

**Comment: Isolation is not defined**

**(D)(1):** Metallic jacketed cable allowed for Source Circuits

**Comment: Why? Modules cannot accept cables and outdoor rated cable (Deck Cable) is very expensive and not commonly available. All chapter 3 wiring methods with two layers of protection would be allowed.**



*Southwest Technology  
Development Institute*

# Grounding

690.41: Systems over 300 volts are not to be grounded

**Comment: Equipment design and cost impacts going ungrounded**

690.46: Solid 6 AWG and smaller EGC and GEC allowed in raceways

690.47(B): AC grounding system permitted for EGC and GEPD on ungrounded DC array

690.47(D): Array grounding for ground or pole mounted arrays.

**Comment: Still does not address bonding. Should reference 250.54**



*Southwest Technology  
Development Institute*

# VI Marking

All Markings and Warnings must comply with new 110.21(B)  
Colors, permanent, environment

690.53(4): PV DC Source will have multiple currents marked

690.56(A/B): **Comment: Has incorrect reference to 690.31(E)**

690.56(B): Will have emergency disconnect warning:

MAXIMUM VOLTAGE AT ARRAY 80VDC AFTER SHUTDOWN



*Southwest Technology  
Development Institute*

# VIII Storage Batteries

Entire part and all sections deleted

**Comment: Many of the PV unique requirements are not found elsewhere in the NEC. Very bad situation. TCC and CMP actions not clear**



*Southwest Technology  
Development Institute*

# 690 odds and ends

690 Part VII: Raises previous 600 volt break point in PV system to 1000 volts.

Part X: Adds Art 625 EV charging requirements



*Southwest Technology  
Development Institute*

# 705 Definitions

705.2 Added Multimode Inverter-same as 690.2



*Southwest Technology  
Development Institute*

# 705.12 Point of Connection

**705.12(D)(2): Use 125% of inverter rated current in calculations, instead of inverter output breaker rating.**

“In systems where inverter output connections are made at feeders, any load taps must be sized based on the sum of 125% of the inverter(s) output circuit current and the rating of the overcurrent device protecting the feeder conductors as calculated in **240.21(B)**.”

**Comment: Appears to allow the use of TAP rules-not clear**



*Southwest Technology  
Development Institute*

## 705.12 Point of Connection (Cont)

Conductors have been removed from the calculations  
Calculations apply to busbars

705.12(D)(2)(a) : 125% inverter output plus utility OCPD shall not exceed busbar rating—general rule, no restrictions on location or loads

705.12(D)(2)(b): Where sources are at opposite ends of bus bar, the 120% allowance applies. Center fed panels not covered



*Southwest Technology  
Development Institute*

## 705.12 Point of Connection (Cont)

705.12(D)(2)(c): The utility OCPD protecting a busbar may not exceed the rating of the busbar.

Ignore the utility OCPD. The sum of all load and supply OCPD may not exceed the rating of the busbar

**Comment: Use OCPD ratings or 125% of inverter ratings?  
(D)(2) says use 125% ???**

705.12(D)(2)(d): P.E. required where multiple ampacity bus or center fed bus is involved



*Southwest Technology  
Development Institute*

# PV Industry Forum Items Not Approved

Definitions related to inverters not fully realized

PV systems definitions not fully clarified

Additional work needed on disconnects

DC to DC converters are not being properly addressed

More work needed on 705.12



*Southwest Technology  
Development Institute*