

Rule 21 Status Update

Mark Baldassari

Director, Codes and Standards

Agenda

- **Rule 21 Phase 1 – Autonomous Operation**
 - Beginning
 - Revision process
 - Decision
- **Rule 21 Phase 2 – Communication and Aggregation**
 - Scope and Status
- **Rule 21 Phase 3 – Utility Control of DER**
 - Scope and Status

Rule 21 Phases

- **Phase 1 – Autonomous Functions**
 - Support Anti-Islanding to trip off under ride-through conditions
 - Provide low/high voltage ride-through
 - Provide low/high frequency ride-through
 - Provide volt/var control in autonomous fashion
 - Provide fixed power factor
 - Reconnect by “soft-start” method
- **Phase 2 – Communications Capabilities for Monitoring, Updating Settings and Control**
 - IEC 61850, SEP2 and DNP3
- **Phase 3 –Interactive Functions**
 - Utility control; directly or through aggregator

Rule 21 Phase 1

History and Status

Rule 21 Beginning

- **CPUC adopted Rule 21 in the 1980s to provide interconnection of non-utility owned DEG**
- **Sept, 2011 the Commission initiated Rulemaking (R.) 11-09-011 to revise Electric Tariff Rule 21 governing PG&E, SCE, SDG&E**
- **Modifications to support “smart inverters”**
 - Generate or Absorb reactive power
 - Aid with voltage and frequency regulation
 - Deliver power in four quadrants
 - In combination with a communication link to control DG and storage in accordance with signals from the utility

Rule 21 Revision Process

- **Feb 2013 SIWG Formed**
- **Jan 2014 SIWG Submitted Phase 1 Recommendations**
 - New voltage and frequency ride-through settings
 - Dynamic Volt-var Operations
 - Ramp Rates
 - Fixed Power Factor
 - Soft Start
- **Aug, 2014 Industry Comments were Filed**

Rule 21 Decision

- **Dec, 2014 Decision 14-12-035 issued**
 - **Establishes mandatory date:** shall be the later of December 31, 2015, or 12 months after approval of UL 1741 Supplement SA
 - **Replacement Inverters:** existing inverters allowed to be replaced with an existing inverter not classified as a Smart Inverter, but of equal or greater ability than the original
 - **Volt/Var:** Decision asks utilities to provide detailed specifications and make a proposal within one year's time
 - **Connect/Reconnect Ramp-up Rate:** Ramp-up rate adjustable between 1 and 100% per second
 - **Adjusted Ride-Through Tables:** See below
 - **Harmonizing Rule 21 with FERC:** ALJ asked utilities to seek approval from FERC
 - **Realizing the Value of Smart Inverters:** How is the system owner compensated financially? Decision deferred. Future workshops proposed to address subject

Voltage and Frequency Ride-Through Tables

Table Hh-1: Voltage Ride-Through Table

Region	Voltage at Point of Common Coupling (% Nominal Voltage)	Ride-Through Until	Operating Mode	Maximum Trip Time
High Voltage 2 (HV2)	$V \geq 120$			0.16 sec.
High Voltage 1 (HV1)	$110 < V < 120$	12 sec.	Momentary Cessation	13 sec.
Near Nominal (NN)	$88 \leq V \leq 110$	<u>Continuous Operation</u> <u>Indefinite</u>	Continuous Operation	<u>Continuous Operation</u> <u>Not Applicable</u>
Low Voltage 1 (LV1)	$70 \leq V < 88$	20 sec.	Mandatory Operation	21 sec.
Low Voltage 2 (LV2)	$50 \leq V < 70$	10 sec.	Mandatory Operation	11 sec.
Low Voltage 3 (LV3)	$V < 50$	1 sec.	Momentary Cessation	1.5 sec.

Table Hh-2: Frequency Ride-Through Table

System Frequency Default Settings	Minimum Range of Adjustability (Hz)	Ride-Through Until (s)	Ride-Through Operational Mode	Default Clearing Trip Time (s)
$f > 62$	62 - 64	No Ride Through	Not Applicable	0.16
$60.5 < f \leq 62$	<u>60.1</u> - 62	299	Mandatory Operation	300
$58.5 \leq f \leq 60.5$	<u>Not Applicable</u>	Indefinite	<u>Continuous Operation</u>	<u>Not Applicable</u>
$57.0 \leq f < 58.5$	57 - <u>60.9</u>	299	Mandatory Operation	300
$f < 57.0$	53 - 57	No Ride Through	Not Applicable	0.16

Rule 21 Phase 1 Standards Development

- **UL 1741 SA**
 - Working Group developing Supplemental Amendment
 - Draft was circulated and comments were due July 2015
 - WG in process of addressing comments, estimated completion Oct 2015
 - STP votes on proposal
 - UL publishes standard, November of 2015
 - Rule 21 effectivity date, estimated November of 2016
- **IEEE 1547 full revision being updated to include Rule 21 requirements, Q4 2016**
- **IEEE 1547.1 full revision will address Rule 21 testing, Q4 2017(?)**

Rule 21 Phase 2

Rule 21, Phase 2

- **Defines Communication Protocols between Utilities and other Parties**
 - IEC 61850 data objects over IEEE 2030.5, SEP2
 - Cyber Security
- **IEEE 1815/DNP3 for Direct SCADA Control and Management**
- **Aggregators can Manage Fleets by Providing Control**
- **Feb, 2015 SIWG Released Phase 2 Recommendations**
- **CPUC kicked back the recommendation to IOUs**
 - IOUs need to generate common protocol document
 - IOUs need to develop individual Generation and Interconnection Handbooks

Rule 21, Phase 2 CSIP

- **From SDG&E, first draft of Common Smart Inverter Profile (CSIP) for California, Draft V0.6.3**
 - Goal is to achieve interoperability with simple data model, messaging model, communication profile, and security
 - Based on IEEE 2030.5
 - Group Management
 - System
 - Sub-transmission
 - Substation
 - Feeder
 - Segment
 - Service Transformer
 - 10 points / curve, 8 curves / inverter - This is a departure from the SIWG recommendations

Rule 21, Phase 2 Handbooks

- **Individual IOUs need to update Generation Interconnection Handbooks, to include:**
 - IEEE 2030.5 implementation guide - Minimum DER Data Exchange Requirements
 - IEEE 2030.5 Optional parameters
 - Data exchange performance requirements
 - Cyber security requirements – Authentication, Authorization, Accountability, and Data Integrity, also key management, certificate authorities and management procedures
 - Cyber security related passwords and cryptographic keys
 - Privacy policies define what is or not publicly available

Phase 3

Just getting started

Phase 3 Scope

- **Functions being proposed – Under Utility control, includes storage**
 - Monitor DER Status and Output
 - Command DER to Connect or Disconnect
 - Set or Limit Maximum Real Power
 - Set Storage Charge/Discharge
 - Counter act voltage and frequency excursions: Frequency-Watt, Voltage-Watt, and Dynamic Reactive Current Support
 - Scheduling of DER and Storage functions
 - Energy Storage Management and Scheduling

Phase 3 Today

- **Aug, 2015, SIWG has Recommendation Document**
- **Many functions are real power limiting and there is a financial tariff needs to be written to compensate owner/operators**
- **Sept. 27, 2015, Phase 3 Workshop**
 - CPUC Auditorium, San Francisco, CA
- **Stay tuned**

Resources



- **Rule 21 Documents (CPUC R. 11-09-11)**
 - [SIWG Phase 2 Recommendations, Draft V9, Feb 2015](#)
 - [CPUC Decision 14-12-035](#)
 - [Rule 21 Ombudsman](#)
- EPRI “[Common Functions for Smart Inverters, Version 3](#)”
- Sandia “[Draft Electric Rule 21 Test Protocols for Advanced Inverter Functions, 19 Dec 2014 Edition](#)”
- IEEE
 - “[IEEE 1547-2003](#)”, Version 26 August 2003
 - “[IEEE 1547a-2014](#)”, Version 20 May 2014
- **UL 1741 SA – Not published at this time**

Questions



