FORM FOR PROPOSAL FOR 2014 NATIONAL ELECTRICAL CODE®

INSTRUCTIONS — PLEASE READ CAREFULLY

Type or print **legibly** in **black** ink. Use a separate copy for each proposal. Limit each proposal to a **SINGLE** section. All proposals **must be received by NFPA by 5 p.m., EST, Friday, November 4, 2011**, to be considered for the 2014 National Electrical Code. Proposals received after 5:00 p.m., EST, Friday, November 4, 2011, will be returned to the submitter. If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

FOR OFFICE USE ONLY
Log #:
Date Rec'd:

alternates of the technical committee. For technical assistance, please call NFPA at 1-800-344-3555.	
Please indicate in which format you wish to receive your ROP/ROC electronic (Note: If choosing the download option, you must view the ROP/ROC from our website; r	
Date 2 Nov 2011 Name John C. Wiles, Jr To	el. No. 575-646-6105
Company Southwest Technology Development Institue, New Mexico State University E	mail jwiles@nmsu.edu
Street Address 3705 RESEARCH DR/MSC 3 SOL City LAS CRUCES St	tate <u>NM</u> Zip <u>88003</u>
***If you wish to receive a hard copy, a street address MUST be provided. Deliveries cannot be made Please indicate organization represented (if any)PV INDUSTRY FORUM . Section/Paragraph690.6(D)	to FO boxes.
e. Proposal Recommends (check one):	ext 🔀 deleted text
b. Proposal (include proposed new or revised wording, or identification of wording to be deleted egislative format; i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through deleted wording).]	
Delete this section and renumber remaining section.	
Alternating current module systems shall be permitted to use a singletect only ac ground faults and to disable the array by removing ac	
Statement of Problem and Substantiation for Proposal: (Note: State the problem that would be repecific reason for your Proposal, including copies of tests, research papers, fire experience, etc. If more publication.)	
The existing text is deleted because there is no readily available equ	1

The existing text is deleted because there is no readily available equipment that can perform the function. The ac output of these ac PV modules is connected to a circuit that is in fact a branch circuit. There are no exposed receptacles and the circuit usually terminates in a non-accessible area like the roof. There is no current requirement for an ac ground fault protector on this circuit. Uninformed PV installers are attempting to install standard GFCIs to meet this requirement and such devices can be damaged when backfed.

- 5. Copyright Assignment
 - (a) I am the author of the text or other material (such as illustrations, graphs) proposed in the Proposal.
 - (b) Some or all of the text or other material proposed in this Proposal was not authored by me. Its source is as follows: (please identify which material and provide complete information on its source)

I hereby grant and assign to the NFPA all and full rights in copyright in this Proposal and understand that I acquire no rights in any publication of NFPA in which this Proposal in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in materials that I have identified in (b) above, I hereby warrant that I am the author of this Proposal and that I have full power and authority to enter into this assignment.

John C. Wiles, Jr.

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

Mail to: Secretary, Standards Council · National Fire Protection Association 1 Batterymarch Park · Quincy, MA 02169-7471 OR

Fax to: (617) 770-3500 OR Email to: proposals_comments@nfpa.org 8/5/2010