

FORM FOR COMMENT FOR 2014 NATIONAL ELECTRICAL CODE®

INSTRUCTIONS — PLEASE READ CAREFULLY

Type or print **legibly**. Use a separate copy for each comment. Limit each comment to a **SINGLE** section. All comments **must be received by NFPA by 5 p.m., EDST, Wednesday, October 17, 2012**, to be considered for the 2014 National Electrical Code. Comments received after 5:00 p.m., EDST, Wednesday, October 17, 2012, will be returned to the submitter.

For technical assistance, please call NFPA at 1-800-344-3555.

FOR OFFICE USE ONLY

Log #: _____

Date Rec'd: _____

Please indicate in which format you wish to receive your ROP/ROC ☒ electronic ☐ paper ☐ download
(Note: If choosing the download option, you must view the ROP/ROC from our website; no copy will be sent to you.)

Date 15 OCT 2012 Name JOHN C. WILES, JR. Tel. No. 575-646-6105

Company SOUTHWEST TECHNOLOGY DEVELOPMENT INSTITUTE/NMSU Email jwiles@nmsu.edu

Street Address 3705 RESEARCH DRIVE City LAS CRUCES State NM Zip 88003

***If you wish to receive a hard copy, a street address **MUST** be provided. Deliveries cannot be made to PO boxes.

Please indicate organization represented (if any) PV INDUSTRY FORUM

1. Section/Paragraph 690.31(B)

2. Comment on Proposal No. (from ROP): 4-284a

3. Comment recommends (check one): ☐ new text ☐ revised text ☒ deleted text

4. Comment (include proposed new or revised wording, or identification of wording to be deleted): [Note: Proposed text should be in legislative format; i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

Delete the inserted text and retain the 2011 language.

(B) Identification and Grouping. PV source circuits and PV output circuits shall not be contained in the same raceway, cable tray, cable, outlet box, junction box, or similar fitting as conductors, feeders, branch circuits of other non-PV systems, ~~or inverter output circuits~~ unless the conductors of the different systems are separated by a partition. PV system conductors shall be identified and grouped as required by 690.31(B)(1) through (4). The means of identification shall be permitted by separate color coding, marking tape, tagging, or other approved means.

5. **Statement of Problem and Substantiation for Comment:** (Note: State the problem that would be resolved by your recommendation; give the specific reason for your Comment, including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

The panel was in error in accepting the proposal 4-194. The original language of 690.31(B) provides protections specific to the unique nature of PV sources by limiting conductors, feeders or branch circuits of **non-PV** systems within the same raceway, cable tray, cable, outlet box, junction box, or similar fitting as PV source and output circuits, because a typical person servicing a non-PV circuit expects it to be deenergized after opening all OCPD at the service panel, whereas PV source and output circuits may remain energized whenever the sun is shining. This proposal attempts to layer additional theoretical protections against the potential risk to equipment due to a double fault condition. However, the proposed inclusion of "or inverter output circuits" is contrary to the specific nature of solar inverters, places an unrealistic burden on installers and inspectors, and does not provide the safety the submitter intends.

300.3(C)(1) allows conductors of ac and dc circuits to occupy the same equipment wiring enclosure, cable, or raceway, provided all conductors have an insulation rating equal to at least the maximum circuit voltage applied to any conductor within the enclosure, cable, or raceway. Inverters have, by definition, both AC and DC inputs and outputs, and multi-mode inverters may have multiple inputs and outputs. Many manufacturers have developed balance of system components with both AC and DC circuit routing and OCPD to accommodate these multiple inputs and outputs, and enable safe and practical installation of listed inverters. This proposal would call into question whether those products could be installed as designed and intended. Adequate provisions currently exist to ensure safety in photovoltaic systems – Chapter 3 provides the wiring methods required for safety, 690.15, 16 and 17 require that devices be identified if energized from multiple sources, and 690.4(E) requires service on these systems to be performed only by qualified persons.

The 2011 NEC handbook includes commentary which clarifies the intent of this section by specifically stating this "does not permit the alternating-current branch-circuit conductors that supply an exterior luminaire installed near a roof-mounted PV array to share the same raceway or cable with the conductors of PV source circuits or PV output circuits. Conductors directly related to a specific PV system, such as those in dc and ac output power circuits, may be contained in the same raceway as PV source and output conductors, providing they meet the requirements of 690.4(B)(1) through

(B)(4) and 300.3(C).

6. Copyright Assignment

- (a) ☒ I am the author of the text or other material (such as illustrations, graphs) proposed in the Comment.
- (b) ☐ Some or all of the text or other material proposed in this Comment was not authored by me. Its source is as follows:
(please identify which material and provide complete information on its source)

I hereby grant and assign to the NFPA all and full rights in copyright in this Comment and understand that I acquire no rights in any publication of NFPA in which this Comment in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in materials that I have identified in (b) above, I hereby warrant that I am the author of this Comment and that I have full power and authority to enter into this assignment.

Signature (Required)



PLEASE USE SEPARATE FORM FOR EACH COMMENT

Mail to: Secretary, Standards Council · National Fire Protection Association
1 Batterymarch Park · Quincy, MA 02169-7471 OR
Fax to: (617) 770-3500 OR Email to: proposals_comments@nfpa.org

10/15/2012